



WATER TREATMENT PRODUCTS

2375 Sanders Road • Northbrook, IL 60062 • (847) 205-6000 • FAX (847) 205-6030

QC4-C Water Filter

PERFORMANCE DATA SHEET

4C Cartridge - Part No. EV9601-00

FEATURES

- Finely polishes treated water to premium quality.
- Reduces chlorine taste and odor.
- Reduces dirt, rust, asbestos fibers, and other particulates such as oxidized iron, manganese, and sulfides.
- Reduces parasitic protozoan cysts such as *Giardia*, *Entamoeba*, *Cryptosporidium*.
- Reduces common earthy, moldy, fishy tastes and odors.

HEALTH CLAIM PERFORMANCE CERTIFIED BY NSF/ANSI*

This system has been tested according to ANSI/NSF 42 and 53 for the reduction of the substances listed below. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system, as specified in ANSI/NSF 42 and 53.

Substance	Influent Challenge Concentration	Max. Permissible Product Water Concentration	Reduction Requirements	Minimum Reduction	Average Reduction
AESTHETIC EFFECTS					
Chlorine	2.0 mg/L ± 10%		≥ 50%		95.7%
Particulate, Class I Particles 0.5 - 1 µm	at least 10,000 particles/mL		≥ 85%		99.9%
HEALTH EFFECTS					
Asbestos	10 ⁷ to 10 ⁸ fibers/L > 10 micrometers in length		99%	99.86%	99.86%
Cyst	Minimum 50,000/L		99.95%	99.99%	99.99%
Turbidity	11 mg/L ± 1 NTU	0.5 NTU		99%	99.3%

*Tested using flow rate = 0.5 gpm; pressure = 60 psig; pH = 7.5 ± 0.5; temp. = 20° ± 2.5°C

†NTU = Nephelometric Turbidity Units

OPERATING SPECIFICATIONS





- Capacity: 3,000 gallons (11,350 L)
- Pressure requirement: 10-125 psi (0.7 - 8.6 bar), non-shock
- Temperature: 35-100°F (2-38°C)
- Flow Rate: 0.5 gpm (1.9 Lpm)

GENERAL INSTALLATION/OPERATION/MAINTENANCE REQUIREMENTS

- Space required: 4 x 4 x 18 in. (10 x 10 x 46 cm) including 2-1/2 inches of clear space under unit for cartridge change.
- Install vertically with cartridge hanging down.
- Use minimum length of tubing possible.
- Flush to drain for three minutes to purge air.
- Replace cartridges when capacity is reached, or when flow becomes too slow, but at least annually.

SPECIAL NOTICES

- Installation instructions, parts and service availability, and standard warranty are included with the product when shipped.
- This drinking water system must be maintained according to manufacturer's instructions, including replacement of filter cartridges.
- Do not use with the water that is microbiologically unsafe, or of unknown quality without adequate disinfection before or after the system. Systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.
- The contaminants or other substances removed or reduced by this water treatment system are not necessarily in your water.
- Check for compliance with state and local laws and regulations.
- Tests run under standard laboratory conditions. Actual performance may vary.

NSF's Certification Program
is accredited by the American
National Standards Institute

NSF's Certification Program
is accredited by the Dutch
Council for Accreditation

System Tested and Certified by NSF International against ANSI/NSF Standard 42 and 53 for the reduction of:

Standard No. 42: Aesthetic Effects
Chemical Unit
Taste and Odor Reduction
Chlorine Reduction
Mechanical Filtration Unit
Particulate Reduction, Class I:
99.9+% reduction of particles
one-half micron and larger in size

Standard No. 53: Health Effects
Mechanical Filtration Unit
Turbidity Reduction
Cyst Reduction
Asbestos Reduction

Validated by WQA according to ANSI/NSF 42 and 53 for the claims listed by NSF International.

(BUYER)

(SELLER)

(DATE)

